



**LEGEND:**

	150 mm Welded Mesh Cable Tray.
	2 x P9000 Trunking.
	P1000 Trunking.
	Cable Ladder.
	Return Flange Cable Tray.
	Conduit plus Galvanized draw wire.
	Distribution Board DB-#.
	Manhole for services as indicated on drawing.
	Cable Indication.
	16mm² 3Core cable.

- NOTES:**
- ① Trunking to be mounted to underside of steel structure using sturdy support.
  - ② All unwired conduit shall have galvanized draw wire installed.
  - ③ All unwired wall boxes shall be fitted with a suitable cover.
  - ④ All power, data, telephone, fire detection & access control conduits shall be extended to terminate in the closest wiring duct or cable tray.
  - ⑤ All data, telephone, fire detection & access control conduits which is located above plastered ceilings shall be extended to terminate in the closest ceiling void which is accessible by removing ceiling tiles.

- GENERAL NOTES:**
- 1) ALL UNWIRED CONDUIT SHALL HAVE GALVANIZED DRAW WIRE INSTALLED.
  - 2) ALL UNWIRED WALL BOXES SHALL BE FITTED WITH A SUITABLE COVER.
  - 3) ALL POWER, DATA, TELEPHONE, FIRE DETECTION & ACCESS CONTROL CONDUITS SHALL BE EXTENDED TO TERMINATE IN THE CLOSEST WIRING DUCT OR CABLE TRAY.
  - 4) ALL DATA, TELEPHONE, FIRE DETECTION & ACCESS CONTROL CONDUITS WHICH IS LOCATED ABOVE PLASTERED CEILINGS SHALL BE EXTENDED TO TERMINATE IN THE CLOSEST CEILING VOID WHICH IS ACCESSIBLE BY REMOVING CEILING TILES.
  - 5) ALL EQUIPMENT SHALL BEAR THE APPROVED MARK OF THE SABS.

DATE		BY		DATE		BY	
REV		BY		DATE		BY	
APP		BY		DATE		BY	
DRAWN BY		DATE		DATE		DATE	
SCALE		DATE		DATE		DATE	
15040-77-00-003		1		0		A1	

**PROPOSED ALTERATION AND ADDITION TO TSS INSULATION WORKSHOP AND SHELTERED STORAGE ROSHERVILLE X14**

**WORKSHOP HIGH LEVEL INFRASTRUCTURE**