


ITEM	DESCRIPTION	SUPPLIER	PRODUCT CODE	QTY.
A	34U 1M DEEP CABINET	—	—	1
B	DOOR HANDLES	—	INCL.	2
C	4 FANS	—	INCL.	4
D	INLET FILTER	—	INCL.	2
E	GLAS DOOR	—	INCL.	2
F	DOOR LABEL	—	INCL.	1


ITEM	DESCRIPTION	SUPPLIER	PRODUCT CODE	QTY.
1	20A, 2P, CIRCUIT BREAKER	SIEMENS	5SL6 220-7	1
2	SURGE ARRESTOR TYPE-2	DEINGUARD	952110	1
3	10A, 2P, CIRCUIT BREAKER	SIEMENS	5SL6 210-7	3
4	6A, 2P, CIRCUIT BREAKER	SIEMENS	5SL6 206-7	3
5	PSU – QUINT4-PS/1AC/24DC/20)	PHOENIX CONTACT	2904602	2
6	INDUSTRIAL DEDICATED 16A SWITCHED SOCKET	CRABTREE	7390/D	1
7	CPU TERMINAL BASE	ABB	1B 711F	1
8	CPU MODULE	ABB	PM 783F	1
9	APC-SMART-UPS-X-3000VA-RACK-TOWER-LCD-200-240V	ABB	SMK3000HWC	2
10	SUPPORT BRACKET GY (AB/SS)	PHOENIX CONTACT	0404428	2
11	EARTH BAR 10mm(w) x 3mm(d)	PHOENIX CONTACT	0402174	0.30m
12	EARTH CONNECTION BLOCK	PHOENIX CONTACT	0421029	A/N
13	SLOTTED CABLE DUCT GY 60mm(w) x 40mm(d)	—	—	3m
14	SLOTTED CABLE DUCT GY 20mm(w) x 20mm(d)	—	—	1.2m
15	END STOP CLIP-IN GY	PHOENIX CONTACT	3022276	2
	TERMINAL STRIP MARKER	PHOENIX CONTACT	0803122	2
	FUSE MODULAR TERMINAL BLOCK – UT 4-HESILED 24 (5X20)-FUSE	PHOENIX CONTACT	3046090	10
	FEED-THROUGH TERMINAL BLOCK – UT 2.5-TWIN	PHOENIX CONTACT	3044513	10
	TERMINAL BLOCK END COVER	PHOENIX CONTACT	3047141	1
16	19-INCH RACK MOUNT 1U BLANK PANEL	—	—	12
17	19-INCH RACK MOUNT 4U BLANK PANEL	—	—	3
18	1U BRUSH PANEL	—	—	3
19	NE840 NETWORK SWITCH	ABB	3E5C080211R1	1

PANEL DESCRIPTION	PANEL TAGNUM
PLC PANEL	8000-PLC-01

CIRCUIT BREAKER LIST	
ITEM	DESCRIPTION
Q1	MAIN SWITCH
Q2	24VDC FEED POWER SUPPLY (PSU01)
Q3	SPARE
Q4	SWITCH
Q5	PANEL SOCKET (PL01)
Q6	UPS
Q7	UPS DB (8000-UDB-01)

<p>COPYRIGHT</p> <p>THIS DRAWING IS THE PROPERTY OF PELCHEM AND MAY NOT, WITHOUT THE WRITTEN AUTHORITY OF PELCHEM BE COPIED OR COMMUNICATED TO A THIRD PARTY OR USED EITHER WHOLLY OR IN PART FOR ANY PURPOSE OTHER THAN THAT FOR WHICH IT IS SUPPLIED</p>	<div> <div>RESONANT</div> <div>DRG. No</div> <div>12618-4-11-06-001</div> </div>	<table border="1"> <tr><td>MAINTENANCE</td><td></td><td></td></tr> <tr><td>OPERATION</td><td></td><td></td></tr> <tr><td>COMMISSION</td><td></td><td></td></tr> <tr><td>RISK MAN.</td><td></td><td></td></tr> <tr><td>QUALITY</td><td></td><td></td></tr> <tr><td>SAFETY</td><td></td><td></td></tr> </table>	MAINTENANCE			OPERATION			COMMISSION			RISK MAN.			QUALITY			SAFETY		
MAINTENANCE																				
OPERATION																				
COMMISSION																				
RISK MAN.																				
QUALITY																				
SAFETY																				

REV	DESCRIPTION	BY	CHK'D	DATE	NOT TO SCALE	
00	ISSUED FOR CONSTRUCTION	E.v.V	PR	2020/08/25	DRAWN	EW
					DATE	2019/07/10
					CHECKED DATE	2020/10/22
					 FIRST ISSUE 2020/10/22	
					APPROVED	DATE



RESONANT  
DRG. No 12618-4-11-06-001




2	TITLE:	F2 Road Tanker Filling Station
---	--------	--------------------------------


	DISCIPLINE	NAME	APPROVED	DATE
	CLIENT			
	PROJECTS			
	PROCESS			
	MECHANICAL			
	ELECTRICAL			
	INSTRUMENT.			
	CIVIL			
	MAINTENANCE			
	OPERATION			
	COMMISSION			
	RISK MAN.			
	QUALITY			
	SAFETY			

PROJECT	BUILDING C2 20% F2 FILLING	DESTROY ALL PREVIOUS
---------	-------------------------------	-------------------------

SECTION PLC PANEL GA

DRG. No	-	
---------	---	---

SHEET	1 OF 1	REVISION
-------	--------	----------



## REVISION